REVISIONS				
SYM	DESCRIPTION	PREPARED BY	DATE	APPROVED

EX. BLDG.
NO. 207
F.F.EL.=30.376

EX. BLDG.
NO. 208
F.F.EL.=30.019

EX. BLDG.
NO. 219
F.F.EL.=30.553

OVERHEAD STEAM & CONDENSATE RETURN LINES TO BE REMOVED TO THIS POINT (PLUG EXST. STEAM & CONDENSATE RETURN LINES TO REMAIN)

REMOVE EXST. OVERHEAD STEAM AND CONDENSATE RETURN LINES.

REMOVE EX. GAS METER

EX. O.H. STEAM AND CONDENSATE RETURN

REMOVE EX. FIRE HYDRANT

(REMOVE) EX. UTILITY VAULT

MH-1
TOP EL.=30.50
INV. EL.=27.98

EXST. F.H.

NEW FIRE HYDRANT

REMOVE EX. FIRE HYDRANT

EX. UTILITY VAULTS (REMOVE)

EX. TELE. VAULT

EX. SAN MH.
TOP EL.=30.190
INV. EL.=27.822
SEE NOTE #5

SEE NOTE #5

REMOVE EXST. UTILITY VAULTS

REMOVE STORM INLETS

NEW MEDICAL DENTAL CLINIC
FIN. FL. EL.=30.5

NEW WATER METER AND VAULT. SEE SHT. C-12 FOR DETAILS

NEW GAS METER AND REGULATOR MAX GAS DEMAND= 48 CMH @ 175mm W.C. SEE SHT. C-12 FOR DETAILS

PROVIDE TEMPORARY 50mm WATER LINE DURING PHASE A WORK

EX. SAN MH.
TOP EL.=30.123
INV. EL.=27.974
SEE NOTE #5

REMOVE EX. FIRE HYDRANT

GATE NO. 5
GUARD HOUSE BUILDING NO. 203

EX. BLDG. NO.204

EX. BLDG.
NO. 215
F.F.EL.=30.438

MH-2
TOP EL.=30.50
INV. EL.=28.10

EX. SAN MH.
TOP EL.=29.788
INV. EL.=28.202
SEE NOTE #5

EX. LIFT STATION
TOP EL.=29.665
INV. EL.=27.064

M-2
TOP EL.=29.70
INV. EL.=28.771

C-1
TOP EL.=29.50
INV. EL.=28.982

EX. UTILITY MANHOLE

INV. EL.=28.735

EX. SAN MH.
TOP EL.=29.933
INV. EL.=29.366
SEE NOTE #5

M-1
TOP EL.=29.90
INV. EL.=28.959

EX. STORM INLET

EX. SAN MH.
TOP EL.=29.697
INV. EL.=28.343
SEE NOTE #5

OVERHEAD POWER LINES (3)

L E G E N D

DESCRIPTION	EXISTING	NEW	TO BE REMOVED
BUILDING			
CURB AND GUTTER			
VALLEY GUTTER			
CONCRETE WALK			
SANITARY LINE	ESS	SS	ESS
DOMESTIC WATER LINE	EW	W	EW
STORM DRAIN	ESD	SD	
GAS LINE	EG	G	EG
UNDERGROUND ELECTRIC	EE		
FIRE WATER LINE	EFW	FW	EFW
STEAM LINE	EST		EST
SANITARY MANHOLE	○	● MH-O	
SANITARY CLEANOUT	SCO ○	● CO	
STORM INLET	□	■ D-O	
STORM MANHOLE		● M-O	
FIRE HYDRANT			
POST INDICATOR VALVE		P.I.V.	
PLUG			
CONTRACTOR'S POINT OF CONNECTION NEW TO EXISTING			
POWER POLE	ø		

NOTE:

1. PRIOR TO THE START OF DEMOLITION OR NEW CONSTRUCTION WORK THE CONTRACTOR SHALL FIELD VERIFY THE EXACT LOCATION AND DEPTH OF ALL UNDERGROUND UTILITIES WITHIN THE LIMITS OF NEW CONSTRUCTION.
2. ANY EXISTING AREAS OR STRUCTURES DISTURBED DURING CONSTRUCTION WHICH ARE TO REMAIN SHALL BE RESTORED TO A CONDITION EQUAL TO OR BETTER THAN ORIGINAL CONDITION.
3. DEMOLITION OF EXISTING UTILITIES SHALL BE PHASED SO THAT BUILDINGS 200, 201 AND 202 ARE NOT LEFT WITHOUT UTILITIES WHILE THEY ARE STILL OCCUPIED.
4. SEE ELECTRICAL DRAWING ES1-1 FOR ELECTRICAL DEMOLITION WORK.
5. TOP OF EXISTING MANHOLES SHALL BE ADJUSTED TO FLUSH W/ NEW FINISH GRADES.

SITE UTILITY PLAN

SCALE: 1: 300

1: 300 — 10 0 10 20 30 40 50

GRAPHIC SCALE
(IN METERS)

IF SHEET IS LESS THAN 28"X42", IT IS A REDUCED PRINT. SCALE REDUCED ACCORDINGLY.

C-7

[redacted]

THIS DOCUMENT ORIGINALLY ISSUED AND SEALED BY [redacted]
THIS MEDIA SHOULD NOT BE CONSIDERED A CERTIFIED DOCUMENT.

MEDICAL/DENTAL CLINIC [redacted]

SITE UTILITY PLAN

SIZE	CODE IDENT. NO.	DRAWING NO.
F	XXXXX	[redacted] 8144515
SCALE: AS SHOWN	SPEC. 11996048	CONST. CONTR. NO. [redacted] SHEET 10 OF 316