



REVISIONS				
SYM	DESCRIPTION	PREPARED BY	DATE	APPROVED


- NOTES:
1. MOUNT RACEWAY ON COMM. BACKBOARD APPROXIMATELY 610mm ABOVE FLOOR.
  2. SEE SHEET EP3-1 FOR WORK IN ROOM 1B19.
  3. CIRCUIT 32,34 TO CONNECT TO 20/2 CIRCUIT BREAKER.
  4. COORDINATE MOUNTING HEIGHT OF ELECTRICAL ITEMS IN PIT WITH ELEVATOR SUPPLIER.

WALL MOUNTED  
ELECTRIC METER FOR  
GUARD SHACK AND  
VISITOR CENTER

**ELECTRICAL  
ROOM 1B-23**  
SCALE: 1:25



**POWER  
FIRST FLOOR PLAN  
BLOCK 1B**  
SCALE: 1:50



**1ST FLOOR  
BLOCK 1B  
KEY PLAN**

IF SHEET IS LESS THAN 28"x42", IT IS A REDUCED PRINT. SCALE REDUCED ACCORDINGLY.

EP2-3

MEDICAL/DENTAL CLINIC

POWER - FIRST FLOOR PLAN - BLOCK 1B

SIZE	CODE IDENT. NO.	DRAWING NO.
F	XXXXX	8144781
SCALE:	AS SHOWN	SPEC. 11996048
		SHEET 276 OF 316