

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18

P
O
N
M
L
K
J
I
H
G
F
E
D
C
B
A

P
O
N
M
L
K
J
I
H
G
F
E
D
C
B
A

LIGHTING FIXTURE SCHEDULE

TYPE	DESCRIPTION	LENSE/ LOUVER	AIR FUNCTION	MOUNTING	VOLTS	LAMP DATA			MANUFACTURER AND CATALOG NO.	NOTES		
						NO.	WATTS	CODE				
B	SURFACE MOUNTED FIXTURE (BEDROOMS)	○	N/A	CS	220 50HZ	2	26	26W DOUBLE	LUMAX SP OR APPROVED EQUAL	SURFACE ROUND, 35.5 cm DIA		
C	1219 mm LONG INDUSTRIAL ELECTRONIC BALLAST, RF FILTER AS NOTED	⊖	N/A	CC	220 50HZ	3	32	F32T8	DAY-BRITE #F332T8PP/220 OR APPROVED EQUAL	MOUNT FIXTURE 2438 mm AFF.		
E1	L.E.D. EXIT SIGN, EMERG BATTERY BACK-UP	⊖	N/A	AS SHOWN	220 50HZ	-	-	LED	MCPHILLBEN # 30LC1R/220 OR APPROVED EQUAL	CHEVRONS TO BE KNOCKED OUT ON SITE ACCORDING TO DRAWINGS		
E2	L.E.D. EXIT SIGN, EMERG BATTERY BACK-UP	⊖	N/A	AS SHOWN	220 50HZ	-	-	LED	MCPHILLBEN # 30LC2R/220 OR APPROVED EQUAL	CHEVRONS TO BE KNOCKED OUT ON SITE ACCORDING TO DRAWINGS		
F	EMER. BATTERY PACK FIXTURE, 12V, STEEL HOUSING NI-CAD BATTERY	⊖	N/A	WS 2438 mm AFF	220 50HZ	2	9	-	LITHONIA #ELMANS5B OR APPROVED EQUAL			
K	COMPACT FLUORESCENT DOWNLIGHT	⊖	N/A	CR	220 50HZ	1	32	32W TRIPLE	LIGHTOLIER 8031CLW 6132BU - 220V			
N	L.E.D. WALL MOUNTED M.H. DIECAST ALUMINUM W/LENS	⊖	IMPACT RESISTANT TEMPERED CLASS	SEE ARCH PLANS	220 50HZ	1	37W	HPS	NORTH AMERICAN ENERGY GROUP NFA-37	MEAN LUMENS EQUIVALENT TO 150W METAL HALIDE		
W	SURFACE MOUNTED FLUORESCENT DECORATIVE FIXTURE, ELECTRONIC BALLAST	○	N/A	CS	220 50HZ	2	32	F32T8	LITHONIA #1064032/220/GE8 OR APPROVED EQUAL	SINGLE BALLAST		
WF	WALL BRACKET FLUORESCENT	⊖	N/A	WS	220 50HZ	2	32	F32T8	LITHONIA #MP-2-32-ACF 125-220-GE81015 OR APPROVED EQUAL			
MOUNTING:					AIR FUNCTION							
CS		CEILING, SURFACE		CC#		CEILING, SUSPENDED # FEET AFF		AIR			AIR SUPPLY/RETURN	
CR		CEILING, RECESSED, ACOUSTIC CEILING TILE		WS#		WALL MOUNTED, SURFACE # FEET AFF		HEAT			HEAT REMOVAL	
CG		CEILING, RECESSED, GYPSUM BOARD		WR#		WALL RECESSED, # FEET AFF		DUAL			AIR AND HEAT	
								STATIC			NO AIR FRICTION	

National Institute of Building Sciences
building Smart Alliance
Washington, DC

Barracks 101

Building Information Model Common File

WARNING: All building models provided by buildingSMART alliance are licensed under a Creative Commons Attribution-NonDerivs 3.0 Unported License.
National Institute of Building Sciences
buildingSMARTalliance
Washington, DC 20005

- GENERAL NOTES:**
- ANY OR ALL FIXTURES SHOWN ON THIS SHEET MAY BE SUBSTITUTED WITH AN APPROXIMATE EQUIVALENT FIXTURE FROM ANOTHER MANUFACTURER. THESE PART NUMBERS ARE SHOWN FOR THE SOLE PURPOSE OF DISPLAYING A CERTAIN DESIGN INTENT.
 - PROVIDE HANDHELD REMOTE CONTROL TEST FOR EXIT AND EMERGENCY LIGHTING UNITS PER SPECIFICATION SECTION 16511. PROVIDE MANUFACTURE OPTION INSTALLED INSIDE FIXTURE FOR BOBINE RCT SERIES OR EQUAL.

Rev Number	Description	Date

Release For Construction:		NIBS/Asa
Drawing Title LIGHTING FIXTURE SCHEDULE		
GEO Project Number	Drawing Scale	Phase
AS NOTED	AS NOTED	04W
GEO File Name	GEO Plot Scale	CONCEPT <input type="checkbox"/> 10% <input type="checkbox"/> 5% <input type="checkbox"/> 100% <input type="checkbox"/> FINAL
CBMEL601.DWG	1:1	
Date	NOV-2012	Sheet Number
Drawn By	NIBS	Barracks
Checked By	NIBS	EL601
Project Number		
Classification	UNCLASSIFIED	

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18